

## SANITARY SEWER PIPE REQUIREMENTS

LOCATION / DEPTH	SIZE	PIPE TYPE	NOTES
< 30" COVER	ALL	C-900 PVC DR18	CONC. ENCASE
36" TO 12'	ALL	SDR 35 PVC	
12' TO 22'	ALL	SDR 26 PVC	
22' OR DEEPER	8"-12"	C-900 PVC DR18	
22' OR DEEPER	>12"	C-905 PVC DR18	
UNDER STREETS (OPEN CUT)	8"-12"	C900 PVC DR18	
UNDER STREETS (BORE & CASE)	ALL	SDR 35 PVC WITH JOINT RESTRAINTS	
CREEK CROSSINGS	8"-12"	C-900 PVC DR18	CONC. ENCASE
CREEK CROSSINGS	>12"	C-905 PVC DR18	CONC. ENCASE
WATERLINE WITHIN 2' VERT. OR 10' HORIZ.	8"-12"	C-900 PVC DR18	
WATERLINE WITHIN 2' VERT. OR 10' HORIZ.	>12"	C-905 PVC DR18	

REVISION	BY	DATE	<b>SANITARY SEWER PIPE TABLE STANDARD DETAILS</b>	
			CITY OF JENKS, OKLAHOMA	
			ENGINEERING DEPARTMENT	
			DATE: 4-11-22	STANDARD NO. SAN-01