



MAIN LINE  
 AWWA C900, CL 305, DR 14  
 TAP TO BE AT TOP OF PIPE

## **2" TAP MATERIALS LIST**

1. TAPPING SADDLE: FORD OR SMITH-BLAIR, MODEL 315, SINGLE BAND, IP THREAD.\*
2. CORPORATION STOP: FORD, MODEL #F500-7-NL, IP THREAD x CTS COMPRESSION FITTING.\*\*
3. SERVICE LINE: 2" SCH 80 PVC OR 2" TUFF-TUBE, BLUE.
4. 2" BALL VALVE: FORD, 1/4 TURN W/MALE IP x FLANGE FITTING W/STAINLESS STEEL BOLTS.
5. RUBBER GASKET BETWEEN BALL VALVE AND METER.
6. 2" METER TO BE PROVIDED BY THE CITY OF JENKS AND INSTALLED BY CONTRACTOR.
7. CUSTOMER SERVICE: 2" SCH 80 PVC OR 2" TUFF-TUBE, BLUE, CONNECTED BY CONTRACTOR.
8. METER CAN: BROOKS, MODEL #173018.
9. METER LID: BROOKS, MODEL #1730 W/FLASH COVER.
10. CLEAN RIVER/FILL SAND.

\* RANGE SHALL BE FOR C900 OR DR21 PVC PIPE.

\*\* INSTALL CORPORATION STOP SO OPERATING LEVER IS OVER CENTERLINE OF MAIN.

REVISION	BY	DATE	<b>2" METER SETTING</b>	
			STANDARD DETAILS	
			CITY OF JENKS, OKLAHOMA	
			ENGINEERING DEPARTMENT	
			DATE: 4-11-22	STANDARD NO. WAT-09