



TOP VIEW

SIDE VIEW

NOTES:

1. ALL PIPING AND CONNECTORS SHALL BE BRONZE, EXCEPT TAPPING SADDLE.
2. STAINLESS STEEL BOLTS WILL BE USED ON TAPPING SADDLES.
3. FRAME AND LID FOR VAULT SHALL BE AS SHOWN ON STANDARD DRAWING WAT- 10.
4. PROVIDE PROTECTION (BARRIER) TO PREVENT DAMAGE TO THE ABOVE-GROUND RISER PIPE.

REVISION	BY	DATE	AIR RELIEF VALVE & VAULT STANDARD DETAILS	
			ENGINEERING DEPARTMENT	
			DATE: 4-11-22	STANDARD NO. WAT-07